

C € 0085



CERT

**EC type examination certificate**  
**EG-Baumusterprüfbescheinigung**

**CE-0085CL0069**

Product Identification No.  
Produkt-Identnummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	EC Gas Appliances Directive (2009/142/EC) <i>EG-Gasgeräte-Richtlinie (2009/142/EG)</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	Bosch Thermotechnik GmbH Sophienstraße 30-32, D-35576 Wetzlar
<b>Distributor</b> <i>Vertreiber</i>	Bosch Thermotechnik GmbH Junkersstraße 20-24, D-73249 Wernau
<b>Product Category</b> <i>Produktart</i>	Boilers with flue systems: Condensing water heater (3202)
<b>Product Description</b> <i>Produktbezeichnung</i>	Condensing water heater
<b>Model</b> <i>Modell</i>	Logamax plus GB012-..K
<b>Countries of Destination</b> <i>Bestimmungsländer</i>	BA, BG, GR, HR, HU, PL, RO, RS, RU, TR, UA
<b>Test Reports</b> <i>Prüfberichte</i>	supplement test: B12/03/1475 EU from 28.03.2012 (DBI)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	EU/2009/142/EG (30.11.2009) DIN EN 483 (01.06.2000) DIN EN 483/A2 (01.05.2002) DIN EN 625 (01.10.1995) DIN EN 677 (01.08.1998)
<b>File Number</b> <i>Aktenzeichen</i>	14-0618-GEA

18.09.2014 Rie A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive 2009/142/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-01

DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

**Electrical Data**                    230 V AC, 50 Hz  
**Elektrische Daten**

<b>Appliance Categories</b> <i>Gerätekatgorien</i>	<b>Supply Pressures</b> <i>Versorgungsdrücke</i>	<b>Countries of Destination</b> <i>Bestimmungsländer</i>	<b>Remarks</b> <i>Bemerkungen</i>
I12E3B/P	20, 30 mbar	PL	only for Logamax plus GB012-25K
I12E3B/P	20, 37 mbar	PL	only for Logamax plus GB012-25K
I12H3B/P	20, 30 mbar	GR, HR, RO, TR	only for Logamax plus GB012-25K
I12H3B/P	25, 30 mbar	HU	only for Logamax plus GB012-25K

<b>Type</b> <i>Typ</i>	<b>Technical Data</b> <i>Technische Daten</i>	<b>Remarks</b> <i>Bemerkungen</i>
Logamax plus GB012-25K	nominal heat output: 7,8...25,5 kW nominal heat input (Hi): 8,0...26,5 kW	
Logamax plus GB012-24K	nominal heat output: 7,5...24,0 kW nominal heat input (Hi): 7,5...25,0 kW	

**Hints of Utilization /Remarks**  
**Verwendungshinweise / Bemerkungen**

flue types: C12x, C32x, C52, C82, B22 according to installation manual no. 6720641106, 6 720 812 513 (PL) and 6 720 812 514 (GR)

Additional proved countries of destination, appliance categories and supply pressures:

BG: I12H3B/P (20, 30 mbar) - only for Logamax plus GB012-25K

BA, RS: I12H3B/P (20, 30 mbar) - only for Logamax plus GB012-25K

RU, UA: I12H3B/P (13, 30 mbar) - only for Logamax plus GB012-24K

In Bosnia-Herzegovina, in the Russian Federation, in Serbia and in the Ukraine the CE-marking will be accepted as conformaty approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Bosnia-Herzegovina, by the Russian Federation, Serbia respectively by the Ukraine.